



ecoAIR⁺
Captage aérothermique
ECS, Chauffage

SIMBOLOGY	
×	Shut off valve
□	Filter
✖	Security valve
○	Expansion vessel
○	Circulating Pump
Z	Check valve
▣	2-way valve on-off
▢	Outdoor probe
□ DI	Digital Input
□ DO	Digital Output
□ AI	Analog Input
○ AI	Analog Output
□ AO	Mixing group 0-10 V

- | | |
|-------------------------|-------------------------|
| 1 ecoAIR ⁺ | 6 Filterball |
| 2 Hidrokit HK-EH-S | 7 Ballstop |
| 3 Kit 2 Ecoblock | 8 Groupe départ direct |
| 4 Ballon d'accumulation | 9 Groupe départ mélangé |
| 5 Ballon ECS | 10 Kit easynet |



nc: normally closed
DO: Digital Output
DI: Digital Input
AO: Analog Output
AI: Analog Input

The current document is a basic installation scheme, some extra components could be necessary so that it is necessary that a specialized company correctly designs the installation. Its total or partial use, as well as any reproduction or assignment to third parties is responsibility of the installation company.